S & M 0200

Quantitative Sensing of Mineral Water with Multichannel Taste Sensor

Satoru Iiyama, Miki Yahiro¹ and Kiyoshi Toko²*

Department of Industrial Chemistry, Faculty of Engineering,
Kinki University in Kyushu, Iizuka 820, Japan

¹Department of Living Culture, Kyushu Junior College of Kinki University, Iizuka 820, Japan

²Department of Electronics, Faculty of Engineering, Kyushu University 36, Fukuoka 812, Japan

(Received April 4, 1994; accepted June 8, 1994)

Key words: taste sensor, electric potential, lipid membrane, mineral water, principal component analysis, taste of hard water

The taste of commercial mineral water was investigated using a multichannel taste sensor with lipid membranes. The electric potential pattern constructed of eight outputs from the membranes contains information on the taste quality and intensity. Individual brands of mineral water were clearly distinguished by the patterns of output signals. A two-dimensional taste map was obtained by a principal component analysis of the patterns. The first principal component axis roughly corresponds to the hardness of mineral water, i.e., the concentration of Ca²⁺. On the other hand, the second principal component axis depends on the concentrations of both Ca²⁺ and HCO₃-. The taste of hard water is located between bitter and salty taste qualities.

1. Introduction

Taste can be measured with a multichannel lipid-membrane sensor which responds to different taste qualities by showing unique patterns of sensor output signals. (1-8) The sensor utilizes lipid membranes as transducers of taste substances and a computer as a data analyzer. The transducer transforms taste information generated by chemical substances into electric potential changes. The multichannel taste sensor using lipid membranes does not measure the amount of each taste substance, but the taste quality and also the intensity

^{*} To whom all correspondence should be addressed.